

Contractor: _____

Project: _____

RTSEQ-MDF-4

Four Unit Support

Quantity: _____



Non-penetrating and adjustable condenser support consisting of strut channel framing and recycled rubber bases for safely supporting HVAC units.

Compatible Bases: [RTSF21]

Clearance: Adjustable height 12" - 24".

Maximum Load Weight: 2000lbs total. 500 lbs./unit.

Hardware finish: [Electrogalvanized] or [Stainless Steel].

Framing: Welded 1-5/8" x 3-1/4" solid, and 1-5/8" x 1-5/8" perforated 12ga strut channel

Strut finish: [Electrogalvanized], [Hot Dip Galvanized], or [Stainless Steel].

Installation Instructions:

1. Place bases on roof based on design layout.
2. Preload (1) 3/8" channel nut and bolt into one of the top two holes on the base receiver.
3. Insert upright components into bases with strut opening facing outward. Tighten bolt to 19 ft/lbs. to secure.
4. Attach 90° brackets to uprights at approximate mount height of unit using 1/2" hardware. Hand tighten.
5. Install welded channel framing to the 90° brackets to form the ends of the support. Level in all directions and tighten hardware to 50 ft/lbs.
6. Attach the remaining welded channel to the top *and* bottom of the welded channel using the plate fittings provided. Align the strut with mount holes on the unit and tighten to 50 ft/lbs.
7. Install yellow caps on the tops of the uprights.

